



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

---

Attn:

**Joseph Sbarra  
Louis Berger U.S., Inc  
48 Wall St.  
New York, NY 10005**

9/29/2016

Phone: (212) 612-7900  
Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 9/27/2016. The results are tabulated on the attached data pages for the following client designated project:

**Haldane Schools Lead Testing / 2041420.009.00 / Haldane  
Elementary School**

The reference number for these samples is EMSL Order #011606267. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

---

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.  
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011606267  
 CustomerID: LBAP78  
 CustomerPO:  
 ProjectID:

Attn: **Joseph Sbarra**  
**Louis Berger U.S., Inc**  
**48 Wall St.**  
**New York, NY 10005**

Phone: (212) 612-7900  
 Fax:  
 Received: 09/27/16 4:00 AM

Project: **Haldane Schools Lead Testing / 2041420.009.00 / Haldane Elementary School**

**Analytical Results**

**Client Sample Description** HES-01  
S-CR B-5 Left **Collected:** 9/24/2016 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-02  
S-CR B-5 Right **Collected:** 9/24/2016 **Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-03  
S-CR B-5 Bathroom **Collected:** 9/24/2016 **Lab ID:** 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.54	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-04  
S-CR B3 Left **Collected:** 9/24/2016 **Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.72	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-05  
S-CR B3 Right **Collected:** 9/24/2016 **Lab ID:** 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-06  
S-Room B6 **Collected:** 9/24/2016 **Lab ID:** 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.5	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-07  
S-Room B7 **Collected:** 9/24/2016 **Lab ID:** 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	85.3	5.00	µg/L	9/27/2016	KB	9/28/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011606267  
 CustomerID: LBAP78  
 CustomerPO:  
 ProjectID:

Attn: **Joseph Sbarra**  
**Louis Berger U.S., Inc**  
**48 Wall St.**  
**New York, NY 10005**

Phone: (212) 612-7900  
 Fax:  
 Received: 09/27/16 4:00 AM

Project: **Haldane Schools Lead Testing / 2041420.009.00 / Haldane Elementary School**

**Analytical Results**

**Client Sample Description** HES-08  
 S-TC Coaches Rm By Girls Rm  
**Collected:** 9/24/2016 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.40	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-09  
 F-O/S Gym  
**Collected:** 9/24/2016 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-10  
 F O/S Gym Bottle Filter  
**Collected:** 9/24/2016 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-11  
 S-Rm G6 Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.53	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-12  
 S-O/S Gym Mens Bathroom Left  
**Collected:** 9/24/2016 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-13  
 S-O/S Gym Mens Bathroom Right  
**Collected:** 9/24/2016 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.01	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-14  
 S-O/S Gym Womens Bathroom Left  
**Collected:** 9/24/2016 **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011606267

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**  
**Louis Berger U.S., Inc**  
**48 Wall St.**  
**New York, NY 10005**

Phone: (212) 612-7900  
 Fax:  
 Received: 09/27/16 4:00 AM

Project: **Haldane Schools Lead Testing / 2041420.009.00 / Haldane Elementary School****Analytical Results**

**Client Sample Description** HES-15  
 S-O/S Gym Womens Bathroom Right  
**Collected:** 9/24/2016 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-16  
 B-Ice Machine Rm Left  
**Collected:** 9/24/2016 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-17  
 B-Ice Machine Rm Center  
**Collected:** 9/24/2016 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-18  
 B-Ice Machine Rm Right  
**Collected:** 9/24/2016 **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	103	5.00	µg/L	9/28/2016	LY	9/28/2016	KB

**Client Sample Description** HES-19  
 S Home Corner Rm South  
**Collected:** 9/24/2016 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.15	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-20  
 S-Home Corner Rm North West  
**Collected:** 9/24/2016 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.27	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-21  
 S-Home Corner Rm North East  
**Collected:** 9/24/2016 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.20	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011606267  
 CustomerID: LBAP78  
 CustomerPO:  
 ProjectID:

Attn: **Joseph Sbarra**  
**Louis Berger U.S., Inc**  
**48 Wall St.**  
**New York, NY 10005**

Phone: (212) 612-7900  
 Fax:  
 Received: 09/27/16 4:00 AM

Project: **Haldane Schools Lead Testing / 2041420.009.00 / Haldane Elementary School**

**Analytical Results**

**Client Sample Description** HES-22  
 S-Home Corner Rm Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-23  
 S Kitchen Rinse Sink West  
**Collected:** 9/24/2016 **Lab ID:** 0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	KB

**Client Sample Description** HES-24  
 S-Kitchen North Left  
**Collected:** 9/24/2016 **Lab ID:** 0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.11	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-25  
 S-Kitchen North Right  
**Collected:** 9/24/2016 **Lab ID:** 0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-26  
 S-Kitchen North Hand Wash Station  
**Collected:** 9/24/2016 **Lab ID:** 0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.95	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-27  
 S-Kitchen Rinse Sink East  
**Collected:** 9/24/2016 **Lab ID:** 0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.28	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-28  
 S Kitchen Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011606267  
 CustomerID: LBAP78  
 CustomerPO:  
 ProjectID:

Attn: **Joseph Sbarra**  
**Louis Berger U.S., Inc**  
**48 Wall St.**  
**New York, NY 10005**

Phone: (212) 612-7900  
 Fax:  
 Received: 09/27/16 4:00 AM

Project: **Haldane Schools Lead Testing / 2041420.009.00 / Haldane Elementary School**

**Analytical Results**

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>				
HES-29 F Cafeteria		9/24/2016		0029				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>				
HES-30 S Cafeteria Mens Bathroom		9/24/2016		0030				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	9/28/2016	LY	9/28/2016	KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>				
HES-31 S Cafeteria Womens Bathroom		9/24/2016		0031				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>				
HES-32 S Elementary Wing Boys Bathroom Left		9/24/2016		0032				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	1.53	1.00	µg/L	9/27/2016	KB	9/28/2016	KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>				
HES-33 S Elementary Wing Boys Bathroom Right		9/24/2016		0033				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	4.41	1.00	µg/L	9/27/2016	KB	9/28/2016	KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>				
HES-34 F Elementary Wing By Elevator		9/24/2016		0034				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB
<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>				
HES-35 F CR 117		9/24/2016		0035				
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011606267

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**  
**Louis Berger U.S., Inc**  
**48 Wall St.**  
**New York, NY 10005**

Phone: (212) 612-7900

Fax:

Received: 09/27/16 4:00 AM

Project: Haldane Schools Lead Testing / 2041420.009.00 / Haldane Elementary School

**Analytical Results**

**Client Sample Description** HES-36  
S CR 117  
**Collected:** 9/24/2016 **Lab ID:** 0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.47	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-37  
S Womens Bathrom 115 Left  
**Collected:** 9/24/2016 **Lab ID:** 0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-38  
S Womens Bathrom 115 Center  
**Collected:** 9/24/2016 **Lab ID:** 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-39  
S Womens Bathrom 115 Right  
**Collected:** 9/24/2016 **Lab ID:** 0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-40  
F CR 118  
**Collected:** 9/24/2016 **Lab ID:** 0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.98	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-41  
S CR 118  
**Collected:** 9/24/2016 **Lab ID:** 0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.18	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-42  
F O/S Rm 115 Left  
**Collected:** 9/24/2016 **Lab ID:** 0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011606267

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**  
**Louis Berger U.S., Inc**  
**48 Wall St.**  
**New York, NY 10005**

Phone: (212) 612-7900  
 Fax:  
 Received: 09/27/16 4:00 AM

Project: **Haldane Schools Lead Testing / 2041420.009.00 / Haldane Elementary School****Analytical Results**

**Client Sample Description** HES-43  
 F O/S Rm 115 Right  
**Collected:** 9/24/2016 **Lab ID:** 0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-44  
 F O/S Rm 115 Bottle Filler  
**Collected:** 9/24/2016 **Lab ID:** 0044

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-45  
 S CR 116  
**Collected:** 9/24/2016 **Lab ID:** 0045

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.08	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-46  
 F CR 113  
**Collected:** 9/24/2016 **Lab ID:** 0046

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.14	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-47  
 S CR 113  
**Collected:** 9/24/2016 **Lab ID:** 0047

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.99	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-48  
 S Nurses Office 112  
**Collected:** 9/24/2016 **Lab ID:** 0048

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-49  
 S Nurses Office Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0049

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB



**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011606267  
 CustomerID: LBAP78  
 CustomerPO:  
 ProjectID:

Attn: **Joseph Sbarra**  
**Louis Berger U.S., Inc**  
**48 Wall St.**  
**New York, NY 10005**

Phone: (212) 612-7900  
 Fax:  
 Received: 09/27/16 4:00 AM

Project: **Haldane Schools Lead Testing / 2041420.009.00 / Haldane Elementary School**

**Analytical Results**

**Client Sample Description** HES-50  
 S Bathroom in Rm 108  
**Collected:** 9/24/2016 **Lab ID:** 0050

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-51  
 S Boys Bathroom Rm 109 Left  
**Collected:** 9/24/2016 **Lab ID:** 0051

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-52  
 S Boys Bathroom Rm 109 Center  
**Collected:** 9/24/2016 **Lab ID:** 0052

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-53  
 S Boys Bathroom Rm 109 Right  
**Collected:** 9/24/2016 **Lab ID:** 0053

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-54  
 F O/S Rm 107 Left  
**Collected:** 9/24/2016 **Lab ID:** 0054

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-55  
 F Bottle Filler O/S Rm 107 Left  
**Collected:** 9/24/2016 **Lab ID:** 0055

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-56  
 F O/S Rm 107 Right  
**Collected:** 9/24/2016 **Lab ID:** 0056

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011606267  
 CustomerID: LBAP78  
 CustomerPO:  
 ProjectID:

Attn: **Joseph Sbarra**  
**Louis Berger U.S., Inc**  
**48 Wall St.**  
**New York, NY 10005**

Phone: (212) 612-7900  
 Fax:  
 Received: 09/27/16 4:00 AM

Project: **Haldane Schools Lead Testing / 2041420.009.00 / Haldane Elementary School**

**Analytical Results**

**Client Sample Description** HES-57  
 S CK 103 From North #1  
**Collected:** 9/24/2016 **Lab ID:** 0057

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	106	5.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-58  
 S CK 103 From North #2  
**Collected:** 9/24/2016 **Lab ID:** 0058

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	66.7	5.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-59  
 S CK 103 From North #3  
**Collected:** 9/24/2016 **Lab ID:** 0059

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	59.7	5.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-60  
 S CK 103 From North #4  
**Collected:** 9/24/2016 **Lab ID:** 0060

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	68.4	5.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-61  
 S CK 103 From North #5  
**Collected:** 9/24/2016 **Lab ID:** 0061

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	26.1	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-62  
 S CK 103 From North #6  
**Collected:** 9/24/2016 **Lab ID:** 0062

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.39	1.00	µg/L	9/27/2016	KB	9/28/2016	KB

**Client Sample Description** HES-63  
 S Lab Prep Rm B/W 103 & 101  
**Collected:** 9/24/2016 **Lab ID:** 0063

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	38.9	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011606267  
 CustomerID: LBAP78  
 CustomerPO:  
 ProjectID:

Attn: **Joseph Sbarra**  
**Louis Berger U.S., Inc**  
**48 Wall St.**  
**New York, NY 10005**

Phone: (212) 612-7900  
 Fax:  
 Received: 09/27/16 4:00 AM

Project: **Haldane Schools Lead Testing / 2041420.009.00 / Haldane Elementary School**

**Analytical Results**

**Client Sample Description** HES-65  
 S CR 101 Right **Collected:** 9/24/2016 **Lab ID:** 0065

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.1	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-66  
 S CR 104 Left **Collected:** 9/24/2016 **Lab ID:** 0066

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.26	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-67  
 S CR 104 Right **Collected:** 9/24/2016 **Lab ID:** 0067

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.47	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-68  
 S CR 104 Prep Rm **Collected:** 9/24/2016 **Lab ID:** 0068

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	22.7	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-69  
 S CR 104 Green House **Collected:** 9/24/2016 **Lab ID:** 0069

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	76.9	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-70  
 S Teachers Bathroom E22 **Collected:** 9/24/2016 **Lab ID:** 0070

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-71  
 S Elementary Wing Girls Bathroom Left **Collected:** 9/24/2016 **Lab ID:** 0071

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.17	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011606267  
 CustomerID: LBAP78  
 CustomerPO:  
 ProjectID:

Attn: **Joseph Sbarra**  
**Louis Berger U.S., Inc**  
**48 Wall St.**  
**New York, NY 10005**

Phone: (212) 612-7900  
 Fax:  
 Received: 09/27/16 4:00 AM

Project: **Haldane Schools Lead Testing / 2041420.009.00 / Haldane Elementary School**

**Analytical Results**

**Client Sample Description** HES-72  
 S Elementary Wing Girls Bathroom Right  
**Collected:** 9/24/2016 **Lab ID:** 0072

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-73  
 F Elementary Wing O/S Elevator  
**Collected:** 9/24/2016 **Lab ID:** 0073

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-74  
 S CR 219  
**Collected:** 9/24/2016 **Lab ID:** 0074

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.7	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-75  
 S CR 216  
**Collected:** 9/24/2016 **Lab ID:** 0075

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.34	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-76  
 S Middle School Wing Rm 217 Left  
**Collected:** 9/24/2016 **Lab ID:** 0076

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-77  
 S Middle School Wing Rm 217 Center  
**Collected:** 9/24/2016 **Lab ID:** 0077

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-78  
 S Middle School Wing Rm 217 Right  
**Collected:** 9/24/2016 **Lab ID:** 0078

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011606267  
 CustomerID: LBAP78  
 CustomerPO:  
 ProjectID:

Attn: **Joseph Sbarra**  
**Louis Berger U.S., Inc**  
**48 Wall St.**  
**New York, NY 10005**

Phone: (212) 612-7900  
 Fax:  
 Received: 09/27/16 4:00 AM

Project: **Haldane Schools Lead Testing / 2041420.009.00 / Haldane Elementary School**

**Analytical Results**

<b>Client Sample Description</b>		HES-79 F O/S Rm 217 Left	<b>Collected:</b>		9/24/2016	<b>Lab ID:</b>		0079
<b>Method</b>	<b>Parameter</b>	<b>Result</b>	<b>RL</b>	<b>Units</b>	<b>Prep Date</b>	<b>Analyst</b>	<b>Analysis Date</b>	<b>Analyst</b>
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG
<b>Client Sample Description</b>		HES-80 F O/S Rm 217 Right	<b>Collected:</b>		9/24/2016	<b>Lab ID:</b>		0080
<b>Method</b>	<b>Parameter</b>	<b>Result</b>	<b>RL</b>	<b>Units</b>	<b>Prep Date</b>	<b>Analyst</b>	<b>Analysis Date</b>	<b>Analyst</b>
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG
<b>Client Sample Description</b>		HES-82 S Middle School Wing Girls Bathroom Left	<b>Collected:</b>		9/24/2016	<b>Lab ID:</b>		0082
<b>Method</b>	<b>Parameter</b>	<b>Result</b>	<b>RL</b>	<b>Units</b>	<b>Prep Date</b>	<b>Analyst</b>	<b>Analysis Date</b>	<b>Analyst</b>
200.8	Lead	1.60	1.00	µg/L	9/27/2016	KB	9/27/2016	EG
<b>Client Sample Description</b>		HES-83 S Middle School Wing Girls Bathroom Right	<b>Collected:</b>		9/24/2016	<b>Lab ID:</b>		0083
<b>Method</b>	<b>Parameter</b>	<b>Result</b>	<b>RL</b>	<b>Units</b>	<b>Prep Date</b>	<b>Analyst</b>	<b>Analysis Date</b>	<b>Analyst</b>
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG
<b>Client Sample Description</b>		HES-84 F O/S 2nd FI Lib Left	<b>Collected:</b>		9/24/2016	<b>Lab ID:</b>		0084
<b>Method</b>	<b>Parameter</b>	<b>Result</b>	<b>RL</b>	<b>Units</b>	<b>Prep Date</b>	<b>Analyst</b>	<b>Analysis Date</b>	<b>Analyst</b>
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG
<b>Client Sample Description</b>		HES-85 F O/S 2nd FI Lib Right	<b>Collected:</b>		9/24/2016	<b>Lab ID:</b>		0085
<b>Method</b>	<b>Parameter</b>	<b>Result</b>	<b>RL</b>	<b>Units</b>	<b>Prep Date</b>	<b>Analyst</b>	<b>Analysis Date</b>	<b>Analyst</b>
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG
<b>Client Sample Description</b>		HES-86 F O/S 2nd FI Lib Right Bottle Filler	<b>Collected:</b>		9/24/2016	<b>Lab ID:</b>		0086
<b>Method</b>	<b>Parameter</b>	<b>Result</b>	<b>RL</b>	<b>Units</b>	<b>Prep Date</b>	<b>Analyst</b>	<b>Analysis Date</b>	<b>Analyst</b>
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011606267

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**  
**Louis Berger U.S., Inc**  
**48 Wall St.**  
**New York, NY 10005**

Phone: (212) 612-7900  
 Fax:  
 Received: 09/27/16 4:00 AM

Project: **Haldane Schools Lead Testing / 2041420.009.00 / Haldane Elementary School****Analytical Results**

**Client Sample Description** HES-87  
 B O/S Green House  
**Collected:** 9/24/2016 **Lab ID:** 0087

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.97	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-88  
 B Garden From East #1  
**Collected:** 9/24/2016 **Lab ID:** 0088

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-89  
 B Garden From East #2  
**Collected:** 9/24/2016 **Lab ID:** 0089

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.31	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-90  
 B Garden From East #3  
**Collected:** 9/24/2016 **Lab ID:** 0090

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.19	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-91  
 B Garden From East #4  
**Collected:** 9/24/2016 **Lab ID:** 0091

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** HES-92  
 B Garden From East #5  
**Collected:** 9/24/2016 **Lab ID:** 0092

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.1	1.00	µg/L	9/28/2016	LY	9/28/2016	KB

**Client Sample Description** HES-93  
 B Garden From East #6  
**Collected:** 9/24/2016 **Lab ID:** 0093

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.46	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077  
 Phone/Fax: (856) 303-2500 / (856) 858-4571  
<http://www.EMSL.com> [EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011606267  
 CustomerID: LBAP78  
 CustomerPO:  
 ProjectID:

Attn: **Joseph Sbarra**  
**Louis Berger U.S., Inc**  
**48 Wall St.**  
**New York, NY 10005**

Phone: (212) 612-7900  
 Fax:  
 Received: 09/27/16 4:00 AM

Project: **Haldane Schools Lead Testing / 2041420.009.00 / Haldane Elementary School**

**Analytical Results**

<i>Client Sample Description</i>		<i>Collected:</i>		<i>Lab ID:</i>				
MMR-1 S Utility Rm		9/24/2016	0095					
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG
MMR-2 S Utility Rm Bathroom		9/24/2016	0096					
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG
MMR-3 S Break Room		9/24/2016	0097					
200.8	Lead	1.57	1.00	µg/L	9/27/2016	KB	9/27/2016	EG
MMR-4 S Womens Bathroom		9/24/2016	0098					
200.8	Lead	1.73	1.00	µg/L	9/27/2016	KB	9/27/2016	EG
MMR-5 S Mens Bathroom		9/24/2016	0099					
200.8	Lead	1.07	1.00	µg/L	9/27/2016	KB	9/27/2016	EG
MMR-6 S Faculty Bathroom		9/24/2016	0100					
200.8	Lead	7.21	1.00	µg/L	9/27/2016	KB	9/27/2016	EG
MMR-7 S Utility Rm MM 202		9/24/2016	0101					
200.8	Lead	17.0	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>[EnvChemistry2@emsl.com](mailto:EnvChemistry2@emsl.com)

EMSL Order: 011606267

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**  
**Louis Berger U.S., Inc**  
**48 Wall St.**  
**New York, NY 10005**

Phone: (212) 612-7900

Fax:

Received: 09/27/16 4:00 AM

Project: **Haldane Schools Lead Testing / 2041420.009.00 / Haldane Elementary School****Analytical Results**

**Client Sample Description** DO-1  
B- Garage Rm  
**Collected:** 9/24/2016 **Lab ID:** 0102

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** DO-2  
B- Garage Rm Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0103

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** DO-3  
S Mens Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0104

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.49	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Client Sample Description** DO-4  
S Womens Bathroom  
**Collected:** 9/24/2016 **Lab ID:** 0105

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	9/27/2016	KB	9/27/2016	EG

**Definitions:**

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)